

# HSINTA GT33 H<sub>2</sub> Co-firing Demonstration Project


Hao Hsien Hsu  
April 23 2024

# Outline


- I. Schedule of H<sub>2</sub> co-firing plan**
- II. H<sub>2</sub> co-firing process & equipment architecture**
- III. H<sub>2</sub> co-firing benefit**
- IV. Difficulties for H<sub>2</sub> co-firing**
- V. Conclusions**




# I. Schedule of H<sub>2</sub> co-firing plan




Taipower



# II. H<sub>2</sub> co-firing process & equipment architecture




# II. H<sub>2</sub> composition table



SE Requirement Specifications

ISO 14687 Type I Grade A

Gas constituents	Unit	Value
CH <sub>4</sub>	Vol. %	To be reported
C <sub>2</sub> H <sub>6</sub>	Vol. %	To be reported
C <sub>3</sub> H <sub>8</sub>	Vol. %	To be reported
C <sub>n</sub> H <sub>2n+2</sub>	Vol. %	To be reported
C <sub>n</sub> H <sub>2n</sub>	Vol. %	To be reported
<b>H<sub>2</sub></b>	<b>Vol. %</b>	<b>≥ 98</b>
CO	Vol. %	To be reported
H <sub>2</sub> O	Vol. %	cf. condensation point
N <sub>2</sub> +Ar+CO <sub>2</sub>	Vol. %	≤ 2
O <sub>2</sub>	Vol. %	To be reported


No. 22, Fengling Rd., Xinsai Dist., Tainan City 741, TAIWAN(R.O.C)  
Phone: (06)889-7481  
Fax: (06)889-6843

### Analytical Report

客户名称 Customer Name:	测试编号 Reference:	0227
取热钢瓶 Sample Cylinder:	报告编号 Report No.	TVP-23-12-0227
气体成分 Gas:	灌装日期 Fill Date:	2023/12/09
钢瓶规格 Cylinder Type:	分析日期 Analysis Date:	2023/12/09
灌装压力/重量 Fill Pressure/Weight:	保存期限 Shelf Life:	2023/12/10
钢瓶编号 Cylinder No.:		8180

COMPONENT	SPECIFICATION	CONCENTRATION
H2	99.999%	>99.999%

THC(as CH4)	1	ppm	<0.01	ppm
CO2	0.5	ppm	<0.05	ppm
CO	0.5	ppm	<0.05	ppm
N2	5	ppm	0.126	ppm
H2O	1	ppm	0.126	ppm
O2	1	ppm	0.054	ppm



Analysis Method :  
 \*GOW MAC 816 DID Analyzer.  
 \*HORIBA GA-390E CO CO<sub>2</sub> Analyzer.  
 \*GOW MAC 816 N2 Analyzer.  
 \*SERVOMEX DF-745  
 \*Servomex DF-550E






# III. H<sub>2</sub> co-firing benefit





1. 5% H<sub>2</sub> co-firing can reduce carbon dioxide emissions by **1 ton per hour at full load.**
2. Verification standards:
  - (1) **NO<sub>x</sub> Emissions < 8ppm**
  - (2) 5% H<sub>2</sub> co-firing **can not affect** the power generation **efficiency** of the unit, and the unit **can automatically switch** between H<sub>2</sub> co-firing and non-H<sub>2</sub> co-firing.




# IV. Difficulties for H<sub>2</sub> co-firing



Improvement of hydrogen unloading station pipes and valves



- renew ball valves
- add ball valves
- nitrogen hose and quick Connector
- add flanges



Taipower



# V. Conclusions



- ★ To build the **first** domestic H<sub>2</sub> co-firing gas turbine generator. (The **first** SGT**6**-2000E for H<sub>2</sub> co-firing power generation in the world)
- ★ To establish **operation** and **maintenance** mechanisms and **safety** standards for H<sub>2</sub> co-firing in large-scale Taipower units. (To provide a reference for other H<sub>2</sub> co-firing power generation units in domestic.)







Thank You